

# Electrical Installation Condition Report

Requirements for Electrical Installations - BS 7671:2018+A2:2022  
(IET Wiring Regulations 18th Edition)

## Guidance for recipients:

**This report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. This Report is only valid if accompanied by the Inspection Schedule(s) and the Schedule(s) of Circuit Details and Test Results.
3. The person ordering the Report should have received the original Report and the inspector should have retained a duplicate.
4. The original Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner / occupier with details of the condition of the electrical installation at the time the Report was issued.
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as **C1 (“Danger Present”)**, the safety of those using the installation is at risk, and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as **C2 (“Potentially Dangerous”)**, the safety of those using the installation may be at risk and it is recommended that a skilled person or persons competent in electrical installation work undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation **code FI** the inspection has revealed an apparent deficiency which may result in a code C1 or C2 could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. **For safety reasons**, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under ‘Recommendations’ and on a label at or near to the consumer unit /distribution board (where required).
11. Where the installation includes a residual current device (RCD) it should be tested six-monthly by pressing the button marked ‘T’ or ‘Test’. The device should switch off the supply and should then be switched on to restore the supply. If the device does not switch off the supply when the button is pressed, seek expert advice. **For safety reasons it is important that this instruction is followed.**
12. Where the installation includes an arc fault detection device (AFDD) having a manual test facility it should be tested six-monthly by pressing the test button. Where an AFDD has both a test button and automatic test function, manufacturer’s instructions shall be followed with respect to test button operation.
13. Where the installation includes a surge protective device (SPD) the status indicator should be checked to confirm it is in operational condition in accordance with manufacturer’s information. If the indication shows that the device is not operational, seek expert advice. For safety reasons it is important that this instruction is followed.
14. Where the installation includes alternative or additional sources of supply, warning notices should be found at the origin or meter position or, if remote from the origin, at the consumer unit or distribution board and at all points of isolation of all sources of supply.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)

## A. Details of the Installation

Client	J&P Thomas	Installation	Mains Intake Area
Address	Meadow View Industrial Estate Rose Haven Hamstreet Kent	Address	Meadow View Industrial Estate Hamstreet Kent
Postcode	TN26 2HH	Postcode	TN26 2NR

## B. Reason for Producing this Report

*This form is to be used only for reporting on the condition of an existing installation.*

Insurance

Date(s) on which the inspection and testing were carried out  to

## C. Details of Installation which is the Subject of this Report

Description of premises Domestic  Commercial  Industrial  Other (please specify)

Estimated age of the wiring system  years

Evidence of alterations or addition Yes  No  Not apparent  if 'Yes', estimated  years

Records of installation available Yes  No  Records held by

Date of last inspection  Electrical Installation Certificate No. or previous Inspection Report No.

## D. Extent of Electrical Installation Covered by this Report:

All outgoing circuits

Agreed Limitations and Operational Limitations (Regulations 653.2)  
None

Agreed with:  Extent of Termination Sampling:

The inspection and testing detailed within this report and accompanying schedule has been carried out in accordance with BS 7671: 2018 (IET Wiring Regulations) amended to

It should be noted that cables concealed within trunkings and conduits, under floors, in roof spaces and generally within the fabric of the building or underground have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.

## E. Summary of the Condition of the Installation

Overall assessment of the installation in terms of its suitability for continued use **SATISFACTORY**  **\*UNSATISFACTORY**

General conditions of the installation (in terms of electrical safety)  
Unable to check main incoming fuse for correct size so ive estimated it as 100A.The mainsboards are a mixture of metal and plastic construction with DB1 and DB3 having holes in top and damaged door giving easy access to live parts,also fuses have been removed and cut off cables still connected,one fuse wire has been doubled up to 60 amps on a 32a cable.DB4 fuse carrier is broken so i had to do atemp fix due to live parts on show.The majority of accessories are in working order but there are some broken and will need to be replaced and at points tested the cables are in good condition.

\*An UNSATISFACTORY assessment indicates that dangerous (code C1), or potentially dangerous (code C2) conditions have been identified

## F. Recommendations

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY I/we recommend that any observations classified as 'Danger present' (code C1) or 'Potential dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'Further Investigation required' (code F1). Observations classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken, I/we recommend that the installation is further inspected and tested by  (date) for the following reasons:

All mains boards to be taken out, redundant cables removed and replaced with one new mainsboard to correct all items picked up on test.

## G. Declaration

I/we being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Company	Kingsnorth Electrical Ltd	Inspected and tested by	Mark Smith
Address	Kingswood , Bromley Green Road, Ruckinge, Ashford,	Name:	Terry Clapp
Postcode	TN26 2EG	Signature:	<i>Terry Clapp</i>
Branch No.	001	Position:	Electrician
Scheme No.	NIC029945	Date:	18/04/2023

## H. Schedule(s)

schedule(s) of inspection and  schedule(s) of Circuit Details and Test Results are attached.

The attached schedule(s) are part of this document and this report is valid only when they are attached to it.

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



## I. Supply Characteristics and Earthing Arrangements

Earthing Arrangements TN-S  TN-C-S  TT  Other  Please specify

Number & Type of live conductors AC  DC  No. of phases  No. of wires

**Nature of Supply Parameters (Note: <sup>(1)</sup> by enquiry, <sup>(2)</sup> by enquiry or by measurement)**

Nominal voltage, U/U<sub>0</sub> <sup>(1)</sup>  V Nominal frequency, f<sup>(1)</sup>  Hz Confirmation of supply polarity

Prospective fault current, I<sub>pf</sub> <sup>(2)</sup>  kA External loop impedance, Z<sub>e</sub> <sup>(2)</sup>  Ω

Supply Protective Device BS (EN)  Type  Rated Current  A

No. of Additional Supplies

## J. Particulars of Installation Referred to in this Report

### Means of Earthing

**Details of installation Earth Electrode** (where applicable) Type (e.g. rod(s), tape etc)  Distributors facility  Installation Earth Electrode

Location  Electrode resistance to earth  Ω Maximum Demand (load)  Amps  KVA

Main Protective Conductors	Material	csa	(✓) or Value	(✓) or Value
Earthing Conductor	Copper	16 mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>
Protective Bonding Conductor	Copper	10 mm <sup>2</sup>	Continuity Verified <input checked="" type="checkbox"/>	Connection Verified <input checked="" type="checkbox"/>

Main Supply Conductor	Material	csa	(connection / continuity) (✓) or Value	(✓) or Value
	Copper	35 mm <sup>2</sup>		

**Main Switch** Location

**Fuse/device rating or setting**  A Voltage rating  V

**If RCD main switch:** Rated residual operating current I Δn  mA

Water installation  Ω To structural steel  Ω

Gas installation pipes  Ω To lightning protection  Ω

Oil installation pipes  Ω Other  Ω

BS(EN)  No. of Poles  Current Rating  A Rated time delay  ms Measured operating trip time  ms

## K. Observations

### Explanation of codes

Referring to the attached inspection schedule(s) and schedule(s) of circuit details and test results, and subject to the limitations specified at the Extent and limitations of inspection and testing Section D.

- No remedial work required
- The following observations are made

<b>C1</b>	Danger present. Risk of Injury. Immediate remedial action required.
<b>C2</b>	Potentially dangerous. Urgent remedial action required.
<b>C3</b>	Improvement recommended.
<b>F1</b>	Further Investigation required without delay

Item No.	Observations	Code
1	5.2 Security of fixing (134.1.1)-DB/CU not fixed solidly to supporting structure, unlikely to fall	C3
2	6.4 Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)-There is trunking lid missing exposing single insulated conductors	C2
3	6.12 Coordination between conductors and overload protective devices (433.1; 533.2.1)	NA
4	6.15.1 Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	NA
5	7.3 Condition of enclosure(s) in terms of IP rating (barriers etc.)(416.2)-Top of the DB/CU has an unused opening exceeding IP4X with no access to live parts	C2
6	7.5 Enclosure not damaged/deteriorated so as to impair safety (651.2)-Damaged enclosure, no live parts exposed	C2
7	DB1 mains board cover broken with only one screw holding it back 7.5.1 Presence and effectiveness of obstacles (417.2)	C2
8	Only main switch to turn off DB1 and DB37.6 Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	C3
9	7.10 Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)-There is no RCD test label at the DB/CU	C3
10	7.12 Presence of other required labelling (Please specify) Section 514)-The source of isolation has not been identified on the DB/CU	C3
11	7.13 Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)-The BS 3036 fuse has incorrect gauge of fuse wire	C2
12	7.15 Protection against mechanical damage where cables enter distribution board (522.8.1; 522.8.5; 522.8.11)-The sharp metal edges of the containment have not been provided with protection	C2
13	7.17 RCD(s) provided for fault protection – includes RCBO(s)(411.4.204; 411.5.2; 531.2)-Selectivity not achieved with series-connected RCD Safety concerns present	C2
14	7.18 RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)-No RCD protection for socket-outlets for internal use	C3
15	8.2 Cables correctly supported throughout their run (521.10.202; 522.8.5)	NA
16	wrong size fuse for lights DB78.5 Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	C2
17	8.6 Coordination between conductors and overload protective devices (433.1; 533.2.1)	C2
18	8.7 Adequacy of protective devices: type and rated current for fault protection (411.3)	C2
19	8.8 Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	C3
20	8.10 Cables Concealed Under Floors, Above Ceilings Or In Walls/ Partitions, Adequately Protected Against Damage (522.3.201, 202, 203, 204)	NA
21	8.10.1 Installed in prescribed zones (see Section D. Extent and limitation) (522.6.201, 204)	NA

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR

652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS 7671:2018+A2:2022 (IET Wiring Regulations 18th Edition)



Item No.	Observations	Code
22	8.12.1 For all socket-outlets of rating 32 A or less unless an exception is permitted (411.3.3)-Socket-Outlets: In areas liable to be used by ordinary persons (BA1, BA3) and children (BA2, BA3) - can be used to supply equipment outside - no RCD protection	C2
23	8.12.2 For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)-RCD protection not provided for mobile equipment for use outdoors	C2
24	8.12.3 For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	C3
25	8.12.4 For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	C3
26	8.12.6 For lighting that is accessible to the public (714.411.3.4)	C3
27	9.18 Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))-Covers of accessories in place but not adequately secured, e.g. securing screws loose, tool needed to remove	C3

One of the following codes, as appropriate, has been allocated to each of the observations made above and/or any attached observation sheets to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.

C1 Danger present. Risk of Injury. Immediate remedial action required.	
C2 Potentially dangerous. Urgent remedial action required.	2, 5, 6, 7, 11, 12, 13, 16, 17, 18, 22, 23
C3 Improvement recommended.	1, 8, 9, 10, 14, 19, 24, 25, 26, 27
FI Further Investigation required without delay	

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)



**Outcomes**

Acceptable condition:	Unacceptable condition: State	Improvement recommended:	Further Investigation:	Not Verified:	Limitation:	Not Applicable:	Inadequacies: (Items 1.1 - 1.1.5 Only)
	or						

Item No.	Description	Outcome
----------	-------------	---------

**1.0 INTAKE EQUIPMENT (VISUAL INSPECTION ONLY);**

1.1	Service cable	
1.1.1	Service head	
1.1.2	Earthing arrangement	
1.1.3	Meter tails	
1.1.4	Metering equipment	
1.1.5	Isolator (where present)	
1.1.6	Person ordering work/dutyholder notified (Delete as appropriate) NOTE 1 Where inadequacies in the intake equipment are encountered, which may result in a dangerous or potentially dangerous situation, the person ordering the work and/or dutyholder must be informed. It is strongly recommended that the person ordering the work informs the appropriate authority. NOTE 2 For this section only, where inadequacies are found, an X should be put against the appropriate item and a comment made in Section K	
1.2	Consumer's Isolator (where present)	
1.3	Consumer's meter tails	

**2.0 PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES**

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	

**3.0 AUTOMATIC DISCONNECTION OF SUPPLY**

3.1	<b>Main earthing/bonding arrangements (411.3; Chap 54)</b>	
3.1.1	Presence of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)	
3.1.2	Presence of installation earth electrode arrangement (542.1.2.3)	
3.1.3	Adequacy of earthing conductor size (542.3; 543.1.1)	
3.1.4	Adequacy of earthing conductor connections (542.3.2)	
3.1.5	Accessibility of earthing conductor connections (543.3.2)	
3.1.6	Adequacy of main protective bonding conductor sizes (544.1)	
3.1.7	Adequacy and location of main protective bonding conductor connections (543.3.2; 544.1.2)	
3.1.8	Accessibility of all protective bonding connections (543.3.2)	
3.1.9	Provision of earthing/bonding labels at all appropriate locations (514.13)	
3.2	FELV - requirements satisfied (411.7; 411.7.1)	

**4.0 OTHER METHODS OF PROTECTION (where any of the methods listed below are employed details should be provided on separate sheets)**

4.1	Non-conducting location (418.1)	
4.2	Earth-free local equipotential bonding (418.2)	
4.3	Electrical separation (Section 413; 418.3)	
4.4	Double insulation (Section 412)	
4.5	Reinforced insulation (Section 412)	

**5.0 DISTRIBUTION EQUIPMENT**

5.1	Adequacy of working space/accessibility to equipment (132.12; 513.1)	
5.2	Security of fixing (134.1.1)	
5.3	Condition of insulation of live parts (416.1)	
5.4	Adequacy/security of barriers (416.2)	
5.5	Condition of enclosure(s) in terms of IP rating etc (416.2)	
5.6	Condition of enclosure(s) in terms of fire rating etc. (421.1.6; 421.1.201; 526.5)	
5.7	Enclosure not damaged/deteriorated so as to impair safety (651.2)	
5.8	Presence and effectiveness of obstacles (417.2)	
5.9	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	
5.10	Operation of main switch(es) (functional check) (643.10)	
5.11	Manual operation of circuit-breakers RCDs and AFDDs to prove functionality (643.10)	
5.12	Confirmation that integral test button/switch causes RCD(s) to trip when operated (functional check) (643.10)	
5.13	RCD(s) provided for fault protection – includes RCBO(s) (411.4.204; 411.5.2; 531.2)	
5.14	RCD(s) provided for additional protection / requirements, where required - includes RCBO(s) (411.3.3; 415.1)	
5.15	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	
5.16	Presence of diagrams, charts or schedules at or near equipment, where required (514.9.1)	
5.17	Presence of alternative supply warning notice at or near equipment, where required (514.15)	
5.18	Presence of next inspection recommendation label (514.12.1)	
5.19	Presence of other required labelling (please specify) (Section 514)	

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)



5.20	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	✓
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
<b>5.0 DISTRIBUTION EQUIPMENT CONT.</b>		
5.22	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	✓
5.23	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
<b>6.0 DISTRIBUTION CIRCUITS</b>		
6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Condition of insulation of live parts (416.1)	✓
6.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	C2
6.5	Suitability of containment systems for continued use (including flexible conduit) (Section 522)	✓
6.6	Cables correctly terminated in enclosures (Section 526)	✓
6.7	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
6.8	Examination of cables for signs of unacceptable thermal or mechanical damage/deterioration (421.1; 522.6)	✓
6.9	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.10	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.11	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	✓
6.12	Coordination between conductors and overload protective devices (433.1; 533.2.1)	NA
6.13	Cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.14	Where exposed to direct sunlight, cable of a suitable type (522.11.1)	✓
<b>6.15 CABLES CONCEALED UNDER FLOORS, ABOVE CEILINGS, IN WALLS/PARTITIONS LESS THAN 50 MM FROM A SURFACE, AND IN PARTITIONS CONTAINING METAL PARTS</b>		
6.15.1	Installed in prescribed zones (see Section D. Extent and limitations) (522.6.202)	NA
6.15.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.204)	✓
6.16	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
6.17	Band II cables segregated/separated from Band I cables (528.1)	NA
6.18	Cables segregated/separated from non-electrical services (528.3)	✓
6.19	Condition of circuit accessories (651.2)	✓
6.20	Suitability of circuit accessories for external influences (512.2)	✓
6.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
6.22	Adequacy of connections, including cpc's, within accessories and to fixed and stationary equipment – identify/ record numbers and locations of items inspected (Section 526)	✓
6.23	Presence, operation and correct location of appropriate devices for isolation and switching (Chapter 46; Section 537)	✓
6.24	General condition of wiring systems (651.2)	✓
6.25	Temperature rating of cable insulation (522.1.1; Table 52.1)	✓
<b>7.0 CONSUMER UNIT/DISTRIBUTION BOARD</b>		
7.1	Adequacy of working space / accessibility to consumer unit/distribution board (132.12; 513.1)	✓
7.2	Security of fixing (134.1.1)	✓
7.3	Condition of enclosure(s) in terms of IP rating (barriers etc.)(416.2)	C2
7.4	Condition of enclosure(s) in terms of fire rating etc (421.1.6; 421.1.201; 526.5)	✓
7.5	Enclosure not damaged/deteriorated so as to impair safety (651.2)	C2
7.5.1	Presence and effectiveness of obstacles (417.2)	C2
7.6	Presence of main switch(es), linked where required (462.1; 462.1.201; 462.2)	C3
7.7	Operation of main switch(es) (functional check) (643.10)	✓
7.8	Manual operation of circuit-breakers, RCD(s) and AFDD's to prove functionality (643.10)	✓
7.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)	✓
7.10	Presence of RCD six-monthly test notice at or near equipment, where required (514.12.2)	C3
7.11	Presence of alternative supply warning notice at or near consumer unit/distribution board (514.15)	NA
7.12	Presence of other required labelling (Please specify) Section 514)	C3
7.13	Compatibility of protective devices, bases and other components; correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (411.3.2; 411.4; 411.5; 411.6; Sections 432; 433)	C2
7.14	Single-pole switching or protective devices in line conductors only (132.14.1, 530.3.3))	✓
7.15	Protection against mechanical damage where cables enter distribution board (522.8.1; 522.8.5; 522.8.11)	C2
7.16	Protection against electromagnetic effects where cables enter distribution board (521.5.1)	✓
7.17	RCD(s) provided for fault protection – includes RCBO(s)(411.4.204; 411.5.2; 531.2)	C2
7.18	RCD(s) provided for additional protection/requirements, where required - includes RCBO(s) (411.3.3; 415.1)	C3
7.19	Confirmation of indication that SPD is functional (651.4)	NA
7.20	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓
7.21	Adequate arrangements where a generating set operates as a switched alternative to public supply (551.6)	NA

for Industrial/Commercial Premises

Requirements for Electrical Installations

BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)



7.22	Adequate arrangements where a generating set operates in parallel with public supply (551.7)	NA
<b>8.0 FINAL CIRCUITS</b>		
8.1	Identification of conductors (514.3.1)	✓
8.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	NA
8.3	Condition of insulation of live parts (416.1)	✓
8.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking. (521.10.1)	✓
8.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)	✓
8.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	C2
8.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)	C2
8.7	Adequacy of protective devices: type and rated current for fault protection (411.3)	C2
8.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)	C3
8.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)	✓
8.10	Cables Concealed Under Floors, Above Ceilings Or In Walls/ Partitions, Adequately Protected Against Damage (522.3.201, 202, 203, 204)	NA
8.10.1	Installed in prescribed zones (see Section D. Extent and limitation) (522.6.201, 204)	NA
8.10.2	Incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like (see Section D. Extent and limitations) (522.6.201; 522.6.204)	✓
<b>8.12 PROVISION OF ADDITIONAL PROTECTION/REQUIREMENTS BY 30 mA RCD</b>		
8.12.1	For all socket-outlets of rating 32 A or less unless an exception is permitted (411.3.3)	C2
8.12.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	C2
8.12.3	For cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	C3
8.12.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.203)	C3
8.12.5	Final circuits supplying luminaries within domestic (household) premises (411.3.4)	NA
8.12.6	For lighting that is accessible to the public (714.411.3.4)	C3
8.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)	✓
<b>9.0 FINAL CIRCUITS CONT.</b>		
9.14	Band II cables segregated/separated from Band I cables (528.1)	NA
9.15	Cables segregated/separated from communications cabling (528.2)	✓
9.16	Cables segregated/separated from non-electrical services (528.3)	✓
9.17	Terminations of cables at enclosures - indicate extent of sampling in Section D of the report (Section 526)	✓
9.17.1	Connection soundly made and under no undue strain (526.6)	✓
9.17.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
9.17.3	Connections of live conductors adequately enclosed (526.5)	✓
9.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)	✓
9.18	Condition of accessories including socket-outlets, switches and joint boxes (651.2 (v))	C3
9.19	Suitability of accessories for external influences (512.2)	✓
9.20	Adequacy of working space/accessibility to equipment (132.12; 513.1)	✓
9.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.3)	✓
<b>10.1 ISOLATOR (SECTIONS 460; 537)</b>		
10.1.1	Presence and condition of appropriate devices (Section 462; 537.2.7)	✓
10.1.2	Acceptable location – state if local or remote from equipment in question (Section 462; 537.2.7)	✓
10.1.3	Capable of being secured in the OFF position (462.3)	✓
10.1.4	Correct operation verified (643.10)	✓
10.1.5	Clearly identified by position and/or durable marking (537.2.6)	✓
10.1.6	Warning label posted in situations where live parts cannot be isolated by the operation of a single device (514.11.1; 537.1.2)	✓
<b>10.2 SWITCHING OFF FOR MECHANICAL MAINTENANCE (SECTION 464; 537.3.2)</b>		
10.2.1	Presence and condition of appropriate devices (464.1; 527.3.2)	✓
10.2.2	Acceptable location – state if local or remote from equipment in question (537.3.2.4)	✓
10.2.3	Capable of being secured in the OFF position (462.3)	✓
10.2.4	Correct operation verified (643.10)	✓
10.2.5	Clearly identified by position and/or durable marking (537.3.2.4)	✓
<b>10.3 EMERGENCY SWITCHING/STOPPING (SECTION 465; 537.3.3)</b>		
10.3.1	Presence and condition of appropriate devices (Section 465; 537.3.3; 537.4)	✓
10.3.2	Readily accessible for operation where danger might occur (537.3.3.6)	✓
10.3.3	Correct operation verified (643.10)	✓
10.3.4	Clearly identified by position and/or durable marking (537.3.3.6)	✓
<b>10.4 FUNCTIONAL SWITCHING (SECTION 463; 537.3.1)</b>		
10.4.1	Presence and condition of appropriate devices (537.3.1.1; 537.3.1.2)	✓
10.4.2	Correct operation verified (537.3.1.1; 537.3.1.2)	✓
<b>11.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)</b>		
11.1	Condition of equipment in terms of IP rating etc (416.2)	✓
11.2	Equipment does not constitute a fire hazard (Section 421)	✓

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671:2018+A2:2022 (IET Wiring Regulations 18<sup>th</sup> Edition)



11.3	Enclosure not damaged/deteriorated so as to impair safety (134.1.1; 416.2; 512.2)	✓
11.4	Suitability for the environment and external influences (512.2)	✓
11.5	Security of fixing (134.1.1)	✓
11.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire: List number and location of luminaires inspected (separate page) (527.2)	✓
<b>11.7 RECESSED LUMINAIRES (DOWNLIGHTERS)</b>		
11.7.1	Correct type of lamps fitted (559.3.1)	✓
11.7.2	Installed to minimize build-up of heat by use of "fire rated" fittings, insulation displacement box or similar (421.1.2)	✓
11.7.3	No signs of overheating to surrounding building fabric (559.4.1)	✓
11.7.4	No signs of overheating to conductors/terminations (526.1)	✓
<b>12.0 PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>		
12.1	If any special installations or locations are present, list the particular inspections applied.	N/A
<b>13.0 PROSUMER'S LOW VOLTAGE ELECTRICAL INSTALLATION(S)</b>		
13.1	Where the installation includes additional requirements and recommendations relating to Chapter 82, additional inspection items should be added to the checklist.	N/A

Inspector's Name: Terry Clapp

Signature: *Terry Clapp*

Date: 18/04/2023



**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	J&P Thomas	<b>Installation Address</b>	Mains Intake Area, Meadow View Industrial Estate, Hamstreet, Kent
<b>Client Address</b>	Meadow View Industrial Estate, Rose Haven Hamstreet, Kent	<b>Postcode</b>	TN26 2NR
<b>Client Postcode</b>	TN26 2HH		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location Mains intake Designation DB1 No. of ways 4		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from _____ No. of phases 3 BS(EN) _____ Type _____ Rating _____ A Nominal voltage _____ V RCD BS(EN) _____ Type _____ Rating _____ IΔn mA	
---	--	---	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/L1	Front outside lights	A	D	4	1	1	0.4	3036 Fuse (SE)	null	5	6	7.28	N/A	N/A	N/A	N/A
1/L2	SPARE															
1/L3	SPARE															
2/L1	SPARE															
2/L2	Sub Mains(DB 2)	A	B	1	4	1.5	0.4	3036 Fuse (SE)	null	60	6	0.32	N/A	N/A	N/A	N/A
2/L3	SPARE															
3/TP	SPARE															
4/TP	SPARE															

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 6522000001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	J&P Thomas	<b>Installation Address</b>	Mains Intake Area, Meadow View Industrial Estate , Hamstreet , Kent
<b>Client Address</b>	Meadow View Industrial Estate , Rose Haven Hamstreet , Kent	<b>Client Postcode</b>	TN26 2HH
		<b>Installation Postcode</b>	TN26 2NR

**Distribution board details - Complete in every case**

Location:   
 Designation:   
 No. of ways:   Supply polarity confirmed  Phase sequence confirmed  
 No. of phases:  SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN)   
 Z<sub>db</sub>  Ω Operating at IΔn  ms  
 I<sub>pf</sub>  kA No. of poles  Time delay (if applicable)

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			E <sub>fig 8</sub> check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/L1	NA	NA	NA	N/A	1.04	NA	500	N/A	>299	✓	1.18	N/A	N/A	N/A
1/L2	NA	NA	NA	N/A						N/A		N/A	N/A	N/A
1/L3	NA	NA	NA	N/A						N/A		N/A	N/A	N/A
2/L1	NA	NA	NA	N/A						N/A		N/A	N/A	N/A
2/L2	NA	NA	NA	N/A	0.07	NA	500	N/A	>99.9	✓	0.34	N/A	N/A	N/A
2/L3	NA	NA	NA	N/A						N/A		N/A	N/A	N/A
3/TP	NA	NA	NA	N/A						N/A		N/A	N/A	N/A
4/TP	NA	NA	NA	N/A						N/A		N/A	N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing:

Date(s) dead testing:  To   
 Date(s) live testing:  To

Test instrument serial number(s):

Loop impedance:  Insulation resistance:  Continuity:  RCD:  E/Electrode:

Tested by: Name (capital letters)  Signature   
 Position:  Date:





**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	J&P Thomas	<b>Installation Address</b>	Mains Intake Area, Meadow View Industrial Estate, Hamstreet, Kent
<b>Client Address</b>	Meadow View Industrial Estate, Rose Haven Hamstreet, Kent	<b>Postcode</b>	TN26 2NR
<b>Client Postcode</b>	TN26 2HH		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Mains intake room"/> Designation <input type="text" value="DB 3"/> No. of ways <input type="text" value="4"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text"/> No. of phases <input type="text" value="3"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> IΔn mA	
--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †:	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other Other § <input type="text" value="80%"/> (Ω)	RCD					
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)		
1/TP	SPARE																	
2/TP	SPARE																	
3/TP	SPARE																	
4/L1	Sub Mains(DB 4)	A	C	1	16	10	0.4	88-2 Fuse HRC G	gG	32	6	0.79	N/A	N/A	N/A	N/A		
4/L2	SPARE																	
4/L3	SPARE																	

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡: See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

















**ELECTRICAL INSTALLATION CONDITION REPORT - Circuit Details**

FT/EICR 652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	J&P Thomas	<b>Installation Address</b>	Mains Intake Area, Meadow View Industrial Estate, Hamstreet, Kent
<b>Client Address</b>	Meadow View Industrial Estate, Rose Haven Hamstreet, Kent	<b>Postcode</b>	TN26 2NR
<b>Client Postcode</b>	TN26 2HH		

<b>Distribution board details - Complete in every case</b> SPD Details: Type(s)* T1 <input type="checkbox"/> T2 <input type="checkbox"/> T3† <input type="checkbox"/> N/A <input checked="" type="checkbox"/> Location <input type="text" value="Mains intake room"/> Designation <input type="text" value="DB 7"/> No. of ways <input type="text" value="8"/>		<b>Complete only if the distribution board is not connected directly to the origin of the installation</b> Overcurrent protective device for the distribution circuit: Supply to distribution board is from <input type="text"/> No. of phases <input type="text" value="1"/> BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> A Nominal voltage <input type="text"/> V RCD BS(EN) <input type="text"/> Type <input type="text"/> Rating <input type="text"/> IΔn mA	
--	--	--	--

**SCHEDULE OF CIRCUIT DETAILS**

Circuit No. and Line	Circuit designation	Type of wiring	Ref. method †	No. of points served	Circuit conductors csa (mm²)		Maximum disconnection time (BS 7671) (S)	Overcurrent protective devices			Breaking capacity (KA)	BS 7671 Max. permitted Zs Other § 80% (Ω)	RCD			
					L / N	CPC		BS EN Number	Type No.	Rating (A)			BS EN Number	Type No.	IΔn (mA)	Rating (A)
1/S	Lights	A	C	7	1	1	0.4	60898 MCB Type B	B	32	6	1.09	61008	AC	30	63
2/S	Skt Ring Circuit	A	C	5	2.5	1.5	0.4	60898 MCB Type B	B	32	6	1.09	61008	AC	30	63
3/S	Lights	A	C	2	1	1	0.4	60898 MCB Type B	B	6	6	5.82	61008	AC	30	63
4/S	SPARE															
5/S	SPARE															
6/S	SPARE															
7/S	SPARE															
8/S	SPARE															

Wiring Types: **A** PVC/PVC, **B** PVC cables in metallic Conduit, **C** PVC cables in non-metallic Conduit, **D** PVC cables in metallic trunking, **E** PVC cables in non-metallic trunking, **F** PVC/SWA cables, **G** SWA/XPLE cables, **H** Mineral Insulated, **MW** Metal Work, **FM** Ferrous Metal, **O** Other

\* SPD Type. Where a combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both boxes.  
 † Where a T3 SPD is installed to protect sensitive equipment, enter Details of Circuits, of the Schedule of Test Results. (See Section 534 of BS 7671:2018+A2:2022.)  
 ‡ See Table 4A2 of Appendix 4 of BS 7671:2018+A2:2022.  
 § Where the maximum permitted earth fault loop impedance value stated in Max Zs column is taken from a source other than the tabulated values given in Chapter 41 of BS 7671:2018+A2:2022, state the source of the data in the appropriate cell for the circuit in the change to Schedule of Test Results

**ELECTRICAL INSTALLATION CONDITION REPORT - Test Results**

FT/EICR 652200001899

for Industrial/Commercial Premises

Requirements for Electrical Installations  
BS7671 :2018+A2:2022 (IET Wiring Regulations 18th Edition)



<b>Client Name</b>	J&P Thomas	<b>Installation Address</b>	Mains Intake Area, Meadow View Industrial Estate , Hamstreet , Kent
<b>Client Address</b>	Meadow View Industrial Estate , Rose Haven Hamstreet , Kent	<b>Client Postcode</b>	TN26 2HH
		<b>Installation Postcode</b>	TN26 2NR

**Distribution board details - Complete in every case**

Location: Mains intake room  
 Designation: DB 7  
 No. of ways: 8  Supply polarity confirmed  Phase sequence confirmed  
 No. of phases: 1 SPD:  Operational status confirmed  Not applicable

**Complete only if the distribution board is not connected directly to the origin of the installation**

Associated RCD (if any): BS (EN) \_\_\_\_\_  
 Z<sub>db</sub> \_\_\_\_\_ Ω Operating at IΔn \_\_\_\_\_ ms  
 I<sub>pf</sub> \_\_\_\_\_ kA No. of poles \_\_\_\_\_ Time delay (if applicable) \_\_\_\_\_

**TEST RESULTS**

Circuit No. and Line	Circuit impedance Ω				Insulation resistance (Record lower reading)			Polarity	Max. Measured Z <sub>s</sub> (Ω)	RCD testing All RCDs IΔn ms	Manual test button operation			
	Ring final circuits only			E <sub>fig 8</sub> check (✓)	R1R2 or R2		Test voltage V				L/L, L/N M(Ω)	L/E, N/E M(Ω)	RCD (✓)	AFDD (✓)
	r1	r <sub>m</sub>	r2		R1 + R2	R2								
1/S	NA	NA	NA	N/A	0.25	NA	500	N/A	>299	✓	0.55	10.0	N/A	N/A
2/S	0.40	0.38	0.57	✓	0.33	NA	500	N/A	>299	✓	0.51	10.0	N/A	N/A
3/S	NA	NA	NA	N/A	0.38	NA	500	N/A	>299	✓	0.68	10.0	N/A	N/A
4/S	NA	NA	NA	N/A						N/A			N/A	N/A
5/S	NA	NA	NA	N/A						N/A			N/A	N/A
6/S	NA	NA	NA	N/A						N/A			N/A	N/A
7/S	NA	NA	NA	N/A						N/A			N/A	N/A
8/S	NA	NA	NA	N/A						N/A			N/A	N/A

Details of circuits and/or installed equipment vulnerable to damage when testing: None

Date(s) dead testing: 18/04/2023 To 18/04/2023  
 Date(s) live testing: 18/04/2023 To 18/04/2023

Test instrument serial number(s):  
 Loop impedance: 792024911E18048 Insulation resistance: 792024911E18048 Continuity: 792024911E18048 RCD: 792024911E18048 E/Electrode: 792024911E18048

Tested by: Name (capital letters) TERRY CLAPP Signature:   
 Position: Electrician Date: 18/04/2023

# ELECTRICAL INSTALLATION CONDITION REPORT

FT/EICR 6522000001899

Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18<sup>th</sup> Edition)




## Generic Continuation


A large, empty rectangular box with a thin black border, intended for the continuation of the report's content.


for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Item	Photograph of Observation	Observation Details
1		Down lights in mains room

Item	Photograph of Observation	Observation Details
2		


Item	Photograph of Observation	Observation Details
3		Fuses can be put back in on redundant cables



for Industrial/Commercial Premises



Requirements for Electrical Installations  
BS 7671:2018 (IET Wiring Regulations 18th Edition)

Item	Photograph of Observation	Observation Details
4	 A photograph showing an electrical control panel. The panel is white and has several blue and red wires connected to it. There are also some white wires. The panel is mounted on a wooden surface. The text 'Use Terminals Behind This Cover' is visible on the panel.	